

Village of Canton Fire and Property Maintenance Inspection Field Report

Name: _____ Address: _____
 Date: _____ C.E.O: _____ Fee: _____ Insurance Co _____
 Construction Type: _____ Code Classification: _____ Zoning: _____ Yr Constructed: _____
 Ansul, Fire suppression system Annual Cert. Date: _____ Alarm System Annual Cert. Date: _____

Initial Inspection-----\$20.00
 1st Follow up inspection-----\$0.00
 2nd Follow up inspection-----\$60.00
 3rd Follow up inspection-----\$250.00
 4th Follow up inspection-----\$1,000.00

Received by : _____ (Owner)(Agent) Date: _____

Follow up inspection: Yes No On or before _____

Kitchen					
Fire Extinguishers in place and operational	Yes	No	N/A	Repair	Replace
GFCI protection 6Ft. From source of Water	Yes	No	N/A	Repair	Replace
Bathroom					
Window or Mech. Vent	Yes	No	N/A	Repair	Replace
GFCI protection 6Ft. From source of Water	Yes	No	N/A	Repair	Replace
Bedroom(s)					
Smoke Detector located inside and outside every bedroom	Yes	No	N/A	Repair	Replace
Emergency Escape and Rescue	Yes	No	N/A	Repair	Replace
General Interior & Exterior					
Exit Signs in place and operational	Yes	No	N/A	Repair	Replace
Exit Doors operational	Yes	No	N/A	Repair	Replace
Storage in exit or exit Components	Yes	No	N/A	Repair	Replace
Fire Extinguishers in place and operational	Yes	No	N/A	Repair	Replace
Emergency lights in place & operational	Yes	No	N/A	Repair	Replace
Combustibles stored in Mech. Elec. Boiler rm/Under Stairs	Yes	No	N/A	Repair	Replace
Non-Conforming use of extension cords	Yes	No	N/A	Repair	Replace
Electrical Panel Clear of obstructions & Covered	Yes	No	N/A	Repair	Replace
Electrical System maintained	Yes	No	N/A	Repair	Replace
Heating system maintained	Yes	No	N/A	Repair	Replace
Plumbing system maintained	Yes	No	N/A	Repair	Replace
Proper Disposal of Garbage & trash	Yes	No	N/A	Repair	Replace
Stairs and-Railings Compliant	Yes	No	N/A	Repair	Replace
Max. Occ. Posted (A occ. only)	Yes	No	N/A	Repair	Replace
Carbon Monoxide Detectors on every floor w/ CO source	Yes	No	N/A	Repair	Replace
Smoke Detectors On every floor including Basement	Yes	No	N/A	Repair	Replace
Bold locks on any means of egress	Yes	No	N/A	Repair	Replace
Hot Water Pressure relief Valve piped 6" off floor	Yes	No	N/A	Repair	Replace
Exterior steps and railings	Yes	No	N/A	Repair	Replace
General house keeping	Good	Fair	Poor	Repair	Replace
ALL ITEMS CHECKED REPAIR IMMEDIATELY					
VIOLATIONS/COMMENTS: SEE PAGE 2					